



425 S. Palos Verdes Street Post Office Box 151 San Pedro, CA 90733-0151 TEL 310-SEA-PORT portoflosangeles.org

Karen Bass Mayor, City of Los Angeles

Board of Harbor Commissioners

Lucille Roybal-Allard President

John A. Pérez Vice President

Yolanda M. De La Torre Commissioner

Edward R. Renwick Commissioner

I. Lee Williams Commissioner

Eugene D. Seroka

Executive Director

DATE: July 2, 2025

SUBJECT: BID NO. 13071, ADDENDUM #1 – FUEL, DIESEL

THAT PORTION WHICH NOW READS IN PART:


BID DUE BEFORE 2:00 PM ON: JULY 8, 2025

IS HEREBY CHANGED TO:

BID DUE BEFORE 2:00 PM ON: JULY 23, 2025

ADD:

Q AND A – (ATTACHED)



Sincerely,

Michelle Davies
SR MANAGEMENT ANALYST

Company Name: _____

Signature: _____

Date: _____

Q:	What is the annual volume of renewable diesel?
A:	11,000 gallons. 2023: 11,947 gallons and 2024:10,862 gallons
Q:	Is the tank above or below ground?
A:	Underground
Q:	Is a bobtail required to make the delivery?
A:	Yes.
Q:	What are the average delivery sizes?
A:	3,000 gallons per delivery
Q:	If renewable diesel is not available, would CARB diesel be acceptable?
A:	Yes.
Q:	What is the delivery hours for the tank?
A:	Normally, Monday to Thursday, from 7:00 a.m. to 3:00 p.m., and Friday 7:00 a.m. to 2:00 p.m.
Q:	What is the location of the tank?
A:	Construction & Maintenance, 500 Pier A Street, Wilmington 90744
Q:	How big is the tank?
A:	6,000 gallons