

<p>May 1, 2025 VERSION: <u>1</u></p>	<p>LOS ANGELES HARBOR DEPARTMENT FY26 Project 65000205, REQUISITION NO. REQ24921 – RFB No. 13145</p>
<p>DESCRIPTION: Cabrillo Beach Youth Aquatic Center – Temporary Power</p>	
<p>Prepared and approved by: Dac Hoang DHoang@portla.org</p>	

GENERAL: It is the intent of this specification to describe in a general form the requirements of the equipment, materials, services and options desired. **Equipment, materials, and services of equal performance and capability, but differing in detail from the specification, may be considered provided they meet the intent of the specifications.** When specifications for a particular item(s) are not defined, the manufacturer's standards are satisfactory.

Bidder must indicate with a check mark, in the spaces provided, after each item, if they COMPLY with the specifications for that item. If they do not comply, each deviation must be described in the space that follows. If insufficient space, indicate "see attached" and describe all deviations on an attachment to the bid. Make sure all deviations are labeled to identify the item for which the deviation is taken. A cover letter must be included indicating that deviations to the specifications are in a separate attachment to the bid. Failure to properly complete this required information will result in the bid being rejected as non-responsive.

<p>GENERAL SCOPE OF WORK: To install 200a 480V 3 Phase breaker in existing panel. A knockout to be made in ex panel, 200a rated flex to be installed carry circuit overhead. (4) 35' poles to be installed at street crossings, approximately (25)35' poles to be used to carry 100a circuits to disconnect locations. A 150KVA step down transformer to be installed to provide 3phase 120/208 at approximately 800 ft; transformer will have load center on secondary side. (3)400A 120/208V 3 Phase CAM Type outlet located at approximate 800 ft, 900 ft, and 1000 ft mark. Alignment total distance is approximately 1000 ft. Bidder is responsible for associated permit for installation. Anticipated rental Period 2 year. Installation to abide by Los Angeles Department of Building and Safety requirement.</p>	<p>Comply: <input type="checkbox"/> Deviation:</p>
<p>TO BE PROVIDED BY SELECTED VENDOR: Crew, equipment and materials to complete all work as specified, equipment rental fees, equipment delivery cost, equipment removal cost, warranty costs, permitting cost pass-through.</p>	<p>Comply: <input type="checkbox"/> Deviation:</p>
<p>1. Permit- obtain LADBS permits required to install temporary electrical installation.</p>	<p>Comply: <input type="checkbox"/> Deviation:</p>
<p>2. (3)400A, Cam Type, outlet with disconnect.</p>	<p>Comply: <input type="checkbox"/> Deviation:</p>

<p>May 1, 2025 LOS ANGELES HARBOR DEPARTMENT VERSION: <u>1</u> FY26 Project 65000205, REQUISITION NO. REQ24921 – RFB No. 13145</p>	
<p>DESCRIPTION: Cabrillo Beach Youth Aquatic Center – Temporary Power</p>	
<p>Job Walk:</p> <p>Bidder to attend pre-bid conference and subsequent job walk, scheduled for Tuesday, May 19, 2026 at 9am. Attendance is REQUIRED. Failure to attend will result in immediate disqualification of bid submission.</p> <ul style="list-style-type: none"> • Pre-Bid Conference Location: 500 Pier A Street, Wilmington CA 90744. • Job Site Location: 2800 Via Cabrillo-Marina, San Pedro, Ca 90731 	<p>Comply: <input type="checkbox"/> Deviation:</p>
<p>SUMMARY OF DEVIATIONS:</p>	
<p>FINAL NOTES:</p> <ol style="list-style-type: none"> 1. The Harbor Department is exempt from payment of Federal Excise Taxes and will furnish vendor with tax exemption certification upon request. 2. Vendor to indicate: 	<p>Comply: <input type="checkbox"/> Deviation:</p>

May 1, 2025 VERSION: <u>1</u>		LOS ANGELES HARBOR DEPARTMENT FY26 Project 65000205, REQUISITION NO. REQ24921 – RFB No. 13145	
DESCRIPTION: Cabrillo Beach Youth Aquatic Center – Temporary Power			
a. Contact Person: _____			
b. Phone Number: _____			
c. Email Address: _____			

SUBMITTED BY:

(Name, Title, Phone)

(Signature)

2 nd Level- Requestor
1 st Level- Requestor
2 nd Level- General Supervisor
Sr Management Analyst