

Karen Bass *Mayor, City of Los Angeles*

Board of Harbor
Commissioners

Lucille Roybal-Allard
President

Diane L. Middleton
Vice President

Michael Muñoz
Commissioner

Edward R. Renwick
Commissioner

I. Lee Williams
Commissioner

Eugene D. Seroka

Executive Director

DATE: March 21, 2024

BID NO. F-1203 ADDENDUM NO. 1

DESCRIPTION: REPLACE ONE (1) AIR-COOLED CHILLER, LABOR AND MATERIALS

BID OPENING DATE: APRIL 9, 2024, 2:00 pm

1. ADDITIONAL INFORMATION

ADD-ON OPTIONS

Manufacturer "Carrier" will provide a basic chiller. Add-ons are required as follows:

- Four (4) New Springs for Isolators. Epoxy-coated isolation springs per manufacturer's weight specifications.
- Marine environment coating on condenser coils. Corrosion prevention E-coat.
- Hail guards on condenser coils.

PIPE SIZE

This and other information to be found on spec sheet provided by the manufacturer, "Carrier".

PICTURES

Eight (8) pictures of the chiller to be replaced are attached to this addendum.

SOFTWARE

Contractor shall provide "Carrier Ivue" programming to chiller to integrate with current building automation.

**DESCRIPTION: REPLACE ONE (1) AIR-COOLED CHILLER, LABOR
AND MATERIALS****WORK HOURS**

Rigging with crane can only be done after hours. Connections to electrical, water and programming can be done at regular hours, Monday through Friday, 7am to 6pm.

2. REMINDERS

BID – A hard copy bid must be submitted by the date and time indicated. No emailed bids will be accepted.

SIGNATURE PAGE – Please follow the “Approved Corporate Signature Methods” outlined on page 1 of the bid.

3. EXTEND BID OPENING DATE

FROM: APRIL 2, 2024, 2:00 PM

TO: APRIL 9, 2024, 2:00 pm

All other specifications, terms and conditions shall remain the same.

For questions, please contact Leticia Caldera at lcaldera@portla.org.

Please initial here _____ and attach this addendum to your bid.

Regards,

A handwritten signature in black ink, appearing to read "Leticia Caldera", written in a cursive style.

Leticia Caldera
Management Analyst