



Karen Bass
Board of Harbor Commissioners
Eugene D. Seroka

Mayor, City of Los Angeles

Lucille Roybal-Allard
President

Diane L. Middleton
Vice President

Michael Muñoz
Commissioner

Edward R. Renwick
Commissioner

I. Lee Williams
Commissioner

Executive Director

May 30, 2024

REQUEST FOR BID ADDENDUM #2 – BIDDER QUESTIONS AND ANSWERS

REQUEST FOR BID # F-1207

DESCRIPTION: “REMOVE AND REPLACE DAMAGED ASPHALT, SOUTH FRIES AVE.”

The following questions have been submitted by the approved Bidders for the above-referenced opportunity. The Department’s (LAHD) answers are in red.

1. Please clarify asphalt mix design Port of LA will require for base pave and cap pave. **All ¾, hot 3” bottom, 3” top layer.**
2. Please clarify if the Port of LA will require us to Re-Compact and Re-Grade Subgrade prior to asphalt placement. **Yes, contractor will compact and regrade.**
3. Please clarify if the water meter will be provided by Port of LA. **Yes, water meter will be provided at closest hydrant to jobsite.**
4. Please clarify if contractor will be able to close off all traffic Fries Street for project duration. **Yes, contractor will be permitted to close off lanes as needed.**
5. Will there be a materials escalation clause if Port of LA requires us to hold bids for longer than 120 Days? **If the resulting Contract takes longer than 120 days to execute, and pricing changes during the execution process, a contract amendment will be authorized, provided that proof of pricing increase can be substantiated, by the appropriate documentation, by the Bidder.**
6. What are the project working hours? **Hours are open to contractor. There is no Noise Ordinance in this location.**
7. Will this project require a bid bond? **No Bid Bond will be required**

Please address any questions regarding this bid to:

Jacquelyn Estrada, Contracts and Purchasing Division, jestrada@portla.org
All other requirements remain unchanged.

Very respectfully,

JACQUELYN L. ESTRADA
Procurement Analyst

92312/E-24-6002