



425 S. Palos Verdes Street Post Office Box 151 San Pedro, CA 90733-0151 TEL/TDD 310 SEA-PORT www.portoflosangeles.org

Eric Garcetti *Mayor, City of Los Angeles*

Board of Harbor
Commissioners

Jaime L. Lee
President

Edward R. Renwick
Vice President

Diane L. Middleton
Commissioner

Lucia Moreno-Linares
Commissioner

Anthony Pirozzi, Jr.
Commissioner

Eugene D. Seroka

Executive Director

DATE: November 10, 2022

BID NO. F-1141 ADDENDUM NO. 2

DESCRIPTION: FURNISH AND INSTALL CNG COMPRESSOR SYSTEM

BID OPENING DATE: NOVEMBER 14, 2022, 2:00 pm

1. EXTEND BID OPENING DATE

FROM: NOVEMBER 10, 2022, 2:00 PM

TO: NOVEMBER 14, 2022, 2:00 PM

2. QUESTIONS AND ANSWERS

1) Q: Which agency will perform the inspection? Who should be contacted in regards to permits, prints, etc.?

A: Since we are only replacing a part of the system and not installing a completely new one, it is up to the Vendor to identify the components which will require inspection. Department(s) the Vendor will need to contact for permits, prints, etc. include, but are not limited to, the City of Los Angeles Department of Building and Safety (LADBS).

3. DELETE LANGUAGE

The following language will be removed from the scope of work ("Bauer Spec C23.2 POLA Public Works") and will not be required on the bid:

CNG Storage Spheres: Vendor to supply and install two 48-inch ASME CNG high-pressure storage spheres. One bottom stackable storage sphere and one top mount sphere. Block/bleed and drain valves with 5,000 psi MAWP.

All other specifications, terms and conditions shall remain the same.

For questions, please contact Leticia Caldera at lcaldera@portla.org.

Please initial here _____ and attach this addendum to your bid.

Regards,

Leticia Caldera, Management Analyst