



425 S. Palos Verdes Street Post Office Box 151 San Pedro, CA 90733-0151 TEL 310-SEA-PORT portoflosangeles.org

Karen Bass *Mayor, City of Los Angeles*

Board of Harbor  
Commissioners

Lucille Roybal-Allard  
*President*

John A. Pérez  
*Vice President*

Yolanda M. De La Torre  
*Commissioner*

Edward R. Renwick  
*Commissioner*

I. Lee Williams  
*Commissioner*

Eugene D. Seroka

*Executive Director*

DATE: September 26, 2025

**BID NO. F-1255 ADDENDUM NO. 4**

**DESCRIPTION: REPLACE ONE (1) AIR-COOLED CHILLER, LABOR AND MATERIALS**

**BID DUE DATE: OCTOBER 9, 2025, 2:00 pm**

**1. ADDITIONAL INFORMATION**

The existing roof steel framing is adequate to support the new Chiller (CH-1). The new chiller will be installed at the same location as the previous CH-1 chiller. The roof steel framing was originally designed to support a Chiller CH-1 with an operating weight of 3,969 lbs. The new Chiller (CH-1) has an operating weight of 3,220 lbs and is less than the original support capacity of 3,969 lbs. Therefore, it is acceptable to install the new Chiller (CH-1) as proposed.

Notes:

1. Contractor to ensure side clearances around the chiller are adequate and meet code and industry standards.
2. Chiller installation shall be in accordance with manufacturer's recommendations.

All other specifications, terms and conditions shall remain the same.

For questions, please contact Leticia Caldera at [lcaldera@portla.org](mailto:lcaldera@portla.org).

**Please initial here \_\_\_\_\_ and attach this addendum to your bid.**

Regards,

Leticia Caldera  
Procurement Analyst