



425 S. Palos Verdes Street Post Office Box 151 San Pedro, CA 90733-0151 TEL/TDD 310 SEA-PORT www.portoflosangeles.org

Karen Bass *Mayor, City of Los Angeles*
Board of Harbor Commissioners
Eugene D. Seroka *Executive Director*
Lucille Roybal-Allard *President*
Diane L. Middleton *Vice President*
Michael Muñoz *Commissioner*
Edward R. Renwick *Commissioner*
I. Lee Williams *Commissioner*

DATE: July 16, 2024

BID NO. F-1212 ADDENDUM NO. 3

DESCRIPTION: REPLACE TWO (2) CONDENSING UNITS, LABOR AND MATERIALS

BID OPENING DATE: JULY 23, 2024, 2:00 pm

1. COPPER ITEMS

Addendum No. 1 called for condenser tubes and fins to be all copper for saltwater / ocean environment. We have confirmed with Vertiv/ Liebert that they can make all copper condensing units. The requirement for all-copper items remains.

2. QUESTIONS AND ANSWERS

Q. Is a Microchannel with electrofin acceptable?

A. No.

Q. Is an epoxy coating for the salt water / ocean environment acceptable?

A. No.

All other specifications, terms and conditions shall remain the same.

For questions, please contact Leticia Caldera at lcaldera@portla.org.

Please initial here _____ and attach this addendum to your bid.

Regards,
Leticia Caldera
Management Analyst